



**Grant County**  
**Department of Public Works**  
124 Enterprise St. S.E.  
Ephrata, WA 98823



Serial No. 11-164

## Memo

**To:** ALL PLAN HOLDERS

**From:** Jeff Tincher, P.E.   
Assistant County Road Engineer

**Date:** May 5, 2011

**Re:** 11-SW Road  
CRP 10-10  
RAP Project #1310-01

---

## ADDENDUM #1

The Special Provisions, Plans & Proposal for this project are amended as follows:

### Special Provisions

The following Special Provisions are changed, added and/or supplemented:

#### **Removal of Pavement, Sidewalks, and Curbs**

Section 2-02.3(3) is supplemented with the following:

The Rotomilled Bituminous Pavement from Sta. 88+50 to Sta. 150+00 and Sta. 182+00 to 195+00 shall be used to construct the ditch/fill inslope on the Left Side (north side) of 11-SW at these locations.

### Plans

The following Plan Sheet's are changed, added and/or supplemented:

#### **Sheet #6**

Structure Note #4 – The following notes shall be added; the existing pipe is concrete and shall be extended with a 36" CMP, Bid Item #10. All costs for damming and/or pumping the wasteway water to extend the existing pipe shall be included in Bid Item #10.

#### **Sheet #20**

The crossing pipe shown at approximately Sta. 263+50 shall be relocated to Sta. 262+50 and shall be added as Structure Note #7. The pipe shall be 70 L.F. of Plain Steel Culvert Pipe 0.064 In. Thick – 24" Diameter with 3:1 beveled ends.

#### **Sheet #21**

Structure Note #1 – 120 L.F. of Plain Steel Culvert Pipe 0.064 In Thick – 18" Diameter with 3:1 beveled ends shall be added.

Structure Note #2 – 70 L.F. of Plain Steel Culvert Pipe 0.064 In Thick – 18" Diameter with 3:1 beveled ends shall be added.

Structure Note #3 – 50 L.F. of Plain Steel Culvert Pipe 0.064 In Thick – 12" Diameter with 3:1 beveled ends shall be added.

**Proposal**

The following Bid Item's are changed, added and/or supplemented:

**Bid Item #7**

Plain Steel Culvert Pipe 0.064 In Thick – 12” Diameter; the quantity shall be changed from 115 L.F. to **165 L.F.**

**Bid Item #8**

Plain Steel Culvert Pipe 0.064 In Thick – 18” Diameter; the quantity shall be changed from 351 L.F. to **541 L.F.**

**Bid Item #9**

Plain Steel Culvert Pipe 0.064 In Thick – 24” Diameter; the quantity shall be changed from 40 L.F. to **110 L.F.**

The appropriate location on the proposal will need to be marked to acknowledge receipt of this Addendum.

“TO MEET CURRENT AND FUTURE NEEDS, SERVING TOGETHER WITH PUBLIC AND PRIVATE ENTITIES, WHILE FOSTERING A RESPECTFUL AND SUCCESSFUL WORK ENVIRONMENT.”