

# Request for Information (RFI)

Date: 06/21/16 Request No. 003.1

Project: Ephrata Landfill Pretreatment Facility and Evaporation Pond

Project No.: 555-1860-012

Owner: Grant County Public Works Department & City of Ephrata

Contractor: AM Hardware

Information Request Initiated By: Tommie Waltermire

Regarding: Plan Sheet(s): \_\_\_\_\_ Specification Section: 08 71 00

**Request:**

Stanley Best locksets and cylinders.

Grant County is currently one of our customers and they order Stanley/Best locks.

Prepared By: Tommie Waltermire Date: 06/21/16

**Response Assigned To:**

Project Manager  Project Engineer  Resident Project Representative

**Response:**

Section 08 71 00, Door Hardware, currently requires Schlage locksets in in Paragraph 3.06, Schedule. Lockset requirements shall be changed to Stanley BEST as follows.

DELETE 3.06.A.1.b and REPLACE with:

**b. Deadbolt Lockset:**

- 1) Make: Stanley BEST
- 2) Series and Design: Model number shall be determined through the construction submittal process.
- 3) Strikes: All locksets and deadbolts shall have box strikes with sufficient strike lip protection to protect door trim. All strikes to have curved lip.

DELETE 3.06.A.1.d and REPLACE with:

d. Handle and Lockset:

- 1) Make: Stanley BEST
- 2) Series and Design: Model number shall be determined through the construction submittal process.

DELETE 3.06.A.2.b and REPLACE with:

b. Deadbolt Lockset:

- 1) Make: Stanley BEST
- 2) Series and Design: Model number shall be determined through the construction submittal process.
- 3) Strikes: All locksets and deadbolts shall have box strikes with sufficient strike lip protection to protect door trim. All strikes to have curved lip.

DELETE 3.06.A.2.d and REPLACE with:

d. Handle and Lockset:

- 1) Make: Stanley BEST
- 2) Series and Design: Model number shall be determined through the construction submittal process.

Signed: Ian Sutton, PE Date: 06/23/16

cc: Jeff Tincher, Jerome Wawers, Brandon Ball, Steve Wagner