



GRANT COUNTY
DEPARTMENT OF FACILITIES & MAINTENANCE
P O Box 37
EPHRATA WA 98823
(509) 754-2011 EXT-3276
FAX (509) 754-6007

March 10, 2015 Grant County Storgae Building Project #1503 Addendum #1

This series of questions asked / answered / posted 3/9/2015

1. Exterior Finish Specification. (I Know the existing building is 29 ga. metal I am assuming you want to keep look consistent?)

Answer: Exterior finish should be minimum 29 ga.

2. Insulation value? (Is it for mainly vapor barrier or will you be heating the building at a later date so the Non-residential energy code will have to be met?)

Answer: Building will require a vapor barrier, Building will be used for records retention and will be heated and cooled after building completion, building should meet the non-residential energy code.

3. Interior or the exterior wall finish and or roof. (Pertains to insulation finish.)

Answer: see answer for question #2

4. Submission form for Bid Proposal. I did not see in the bid packet?

Answer: No specific bid requirements as this is based on proposals

5. Building size specifications revised to 96' X 28' X 9' ceiling, Gabled roof

TOM GAINES
FACILITIES & MAINTENANCE MANAGER
TGAINES@GRANTCOUNTYWA.GOV